





























# LEGEND

SYMBOL	DESCRIPTION
	INCANDESCENT OR HID - WALL BRACKET MOUNTED
	FLUORESCENT - SURFACE OR RECESS MOUNTED
	FLUORESCENT ON EMERGENCY/EGRESS CIRCUIT
	DUPLEX RECEPTACLE - WALL MOUNTED
	DUPLEX RECEPTACLE - WALL MOUNTED - WEATHERPROOF
	DUPLEX RECEPTACLE - WALL MOUNTED - GROUND FAULT
	DOUBLE DUPLEX RECEPTACLE - WALL MOUNTED
	DUPLEX RECEPTACLE - WALL MOUNTED ABOVE COUNTER
	DOUBLE DUPLEX RECEPTACLE - WALL MOUNTED ABOVE COUNTER
	SPECIAL OUTLET - WALL MOUNTED
	JUNCTION BOX - CEILING MOUNTED
	JUNCTION BOX - WALL MOUNTED
	JUNCTION BOX FOR TELEPHONE SERVICE - WALL MOUNTED
	JUNCTION BOX FOR SCOREBOARD CONTROL - WALL MOUNTED
	POWER PANEL 208Y/120V
	DISTRIBUTION PANEL/PANELBOARD 480Y/277V
	3/4" PLYWOOD BACKBOARD
	WIRING IN CONDUIT CONCEALED IN WALL OR ABOVE CEILING
	WIRING IN CONDUIT CONCEALED IN OR BELOW SLAB
	WIRING IN FLEXIBLE CONDUIT
	ONE CONDUCTOR PER CROSSHATCH - TWO IF NOT INDICATED
	HOMERUN TO PANEL - ONE CIRCUIT PER ARROW
	NONFUSED DISCONNECT
	MOTOR - FRACTIONAL HORSEPOWER
	ULTRASONIC 360° SENSOR EQUAL TO WATT STOPPER WT-2255
S	SINGLE POLE SINGLE THROW (SPST) - WALL MOUNTED
S <sub>3</sub>	THREE WAY - WALL MOUNTED
S <sub>M</sub>	SINGLE POLE - MOTOR RATED
S <sub>D</sub>	DIMMER SWITCH equal to ACUITY MOD # SPODMRD
S <sub>K</sub>	KEYED SWITCH
S <sub>P</sub>	SPST w/ PILOT LIGHT - WALL MOUNTED
S <sub>I</sub>	MOTION DETECTOR SWITCH - EQUAL TO SENSOR SWITCH WSX
	DUAL TECH MOTION/IR HEAT SENSOR - WALL/CLG MNT EQUAL TO SENSOR SWITCH CM PDT 9
	RELAY CONTROLLED BY MOTION DETECTOR OR SENSOR DEVICE ENCLOSED IN NEMA 1 JB
	CONTACTOR IN NEMA 1 BOX - 20A - 120V RATED ELEC HELD